



PLAN/EAST – WEST STREETS

N.T.S.



GENERAL NOTES:

1. WATER MAIN MUST BE LAID TO GRADE FOLLOWING FINISHED ROAD ELEVATION.
2. COMPACTION AS REQUIRED BY SPOKANE COUNTY STANDARDS OR AS SPECIFIED BY THE DISTRICT.



BACKFILL CHARACTERISTICS

- (N1) NO ROCKS LARGER THAN 12" DIAMETER
- (N2) NO ROCKS LARGER THAN 4" DIAMETER
- (N3) BEDDING—CLEAN, ROUND, GRANULAR SAND OR GRAVEL 3/8 INCH MINUS OR SMALLER

PLAN/NORTH – SOUTH STREETS

N.T.S.

TYPICAL SECTION

N.T.S.

300701-SCD

DATE: 02/01/10

**CONSOLIDATED IRRIGATION
DISTRICT No.19 (C.I.D.#19)
GREENACRES, WA**

WATER MAIN DETAIL

DRAWING No.

W1