

2025 Consumer Confidence Report (Drinking Water Quality)

Mandatory health related standards are established by the Washington State Department of Health

Unit	MCL	MCLG	System ID 10221A				System ID 10220T						
			1	2	3	4	5	6	7	8	9	10	11
Department of Health Reporting ID Sites			S01	S04	S07	S10	S11	S14	S23	S17	S20	S24	S25
384 tests were taken during this reporting period throughout both systems. 1 sample site had total coliform and no E. Coli present.			Total coliform was present at 8th and Hodges w/ follow up tests passing 7/2025										
Total Coliform Bacteria (32 total samples per month) ¹													
System 10221A - 20 tests and System 10220T - 12 tests taken monthly													
Inorganic chemicals													
Inorganic chemicals were tested for during 2018 (next testing 2027)			No (IOC) tests were reported over the MCL levels in 2018 please call for further information										
Nitrates (one per WS every year)	mg/L	10.0000	1.0900	0.4500	0.6300	0.3400	1.5800	1.3100	1.3100	1.4600	1.3400	1.1000	0.9200
Asbestos 2018 last tested (1 sample every 9 years) (next due 2027)	MFL	7.0000	<0.123										
Arsenic - not detected 2025 (standard - every 3 year test well site 11)	mg/L	0.010	0.00645										
Synthetic Organic Compounds													
74 Synthetic Organic Chemicals were tested for during 2018													
Pesticides (every 9 years) due 2027	ppb	varies	No constituents detected										
Herbicides (every 9 years) due 2027	ppb	varies	No constituents detected										
Halo-Acetic Acids (HAA5)(every year)			No constituents detected										
Volatile Organic Compounds													
Volatile Organic Chemicals were tested for during 2022(next testing 2028)			No (VOC) tests were reported over the MCL levels in 2022 please call for further information										
Gross Alpha (every 6 years - due 2027)(sites 6 9 11 standard 3 year tests)	pCi/L	15.0000	0.0000	0.0000	0.0000	0.0000	0.0000	3.6700	0.0000	0.0000	1.8600	0.0000	2.9400
Radium (every 6 years - due 2027) (sites 6 9 11 standard 3 year tests)	pCi/L	5.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.3250	0.0000	0.0000	0.2860	0.0000	0.3090
Trihalomethane (THM) (every year)			No constituents detected										
Soil Fumigants (every 3 years) waiver granted													
Lead and Copper - Regulated at the Consumer's Tap													
50 Samples were taken in 2024 for: ⁵													
Lead (every 3 years - due 2027)	ppb	15.0000	Action levels not exceeded										
Copper (every 3 years - due 2027)	mg/L	1.3000	Action levels not exceeded										
PFAS (Per- and polyfluoroalkyl substances)													
DOH Quarterly samples 2025			Action levels not exceeded										
PFAS (Per- and polyfluoroalkyl substances)			Please call the office with any questions with complete reports in the District office										

Abbreviations & Notes

ppm=parts per million	ppb=parts per billion	mg/L=milligram per liter	pCi/L=picocuries per liter	MFL=million fibers length
AL=Action Level	Concentrations of a constituent which, if exceeded, triggers treatment or other requirements.			
MCL=Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCL's are set at very stringent levels. To understand the possible health effects described from the many regulated constituents, a person would have to drink 2 liters of water every day at the MCL for a lifetime to have a one-in-a-million chance of having the described health effect.			
MCLG=Maximum Contaminant Level Goal	The level of a contaminant in drinking water below which there is no known or expected risk to health.			
TT=Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.			
Federal Action Level	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.			
Errors and Omissions	None during 2024			
Likely Source of Contamination				

¹Naturally present in the environment.

²Industrial or domestic wastewater discharges, mining or farming and livestock productions.

³Byproducts of industrial processes & petroleum production, leaking petroleum storage tanks, cleaning solvent spills/discharges into storm drains or sewers.

⁴Erosion of natural deposits.

⁵Leaching from metal water pipes & fittings.

Lead pipes/service lines. Copper pipes with lead solder installed between 1982-1988. Please contact us if you would like your house added to the list of potential properties to test.